



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	8110-2278:0502
CATEGORY:	8110 - DECKING FOR WILDLAND URBAN INTERFACE (W.U.I)
LISTEE:	MOSO North America, Inc. PO Box 793, Worcester, PA, 19490 Contact: Adamson, Ryan 855-343-8444 Email: radamson@moso-bamboo.com
DESIGN:	Moso "N-Durance" Bamboo Decking boards are comprised of compressed bamboo strips. Nominal 5-1/2" x 3/4" deck boards, with tongue and groove profile ends, fastened to 2" X 4" southern yellow pine joists. Refer to the manufacturer's installation instructions and product data sheets for detailed installation instructions.
RATING:	Tested in accordance with ASTM E84 and SFM 12-7A-4A Flame Spread Index: 10 Smoke Developed Index: 160 Max Flame Front: 2.8 feet Class A Flame Spread
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee name, model number, rating and SFM label
APPROVAL:	Listed as exterior decking for use in the Wildland Urban Interface. Refer to the manufacturer's installation instructions and product data sheets.
NOTES:	Test Protocol SFM 12-7A-4A and ASTM E84

This test report is the property of MOSO North America Inc. The results mentioned in this report are only applicable to the products/materials produced and supplied by MOSO North America Inc., its affiliates or by its authorized affiliates.

10-15-24 MH





**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 10/22/2024

Listing Expires: 06/30/2025

Authorized By: **Michael Huang**, Program Coordinator
Fire Engineering & Investigations Division

This test report is the property of MOSO North America Inc.
The results mentioned in this report are only applicable to the products/materials produced and supplied by MOSO North America Inc., its affiliates or by its authorized affiliates.

This test report is the property of MOSO North America Inc.
The results mentioned in this report are only applicable to the products/materials produced and supplied by MOSO North America Inc., its affiliates or by its authorized affiliates.